

ADEQ

ARKANSAS
Department of Environmental Quality

September 30, 2010

Mayor Marion Gill
City of Dumas
P.O. Box 157
Dumas, AR 71639

RE: NPDES Permit No.: AR0033987 AFIN: 21-00045
Response to Inspection

Dear Mayor Gill:

The Department has received your response to the September 1, 2010 routine compliance inspection of your facility by our District Field Inspector, Steven Henderson. Your letter appears to adequately address the discrepancies identified during the visit however, it is imperative that you have the flow meter calibrated by an outside source at least once every year. The Department assumes the corrective actions taken will be maintained to ensure consistent compliance with the requirements of the permit. Acceptance of this response by the Department does not preclude any future enforcement action deemed necessary at this site or any other site.

The Department will keep the inspection and response on file. If future violations occur that require enforcement action, the Department will consider the inspection and response as required by the Pollution Control and Ecology Commission Regulation No. 7, Civil Penalties. This regulation requires the Department to consider the past history of your site and how expeditiously the violations were addressed in determining any civil penalty that may be necessary for any future violations.

If we need further information concerning this matter, we will contact you. Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0649 or you may e-mail me at sawyer@adeq.state.ar.us.

Sincerely,



Sam Sawyer
Enforcement Coordinator
Water Division Enforcement Branch