

## NON-COMPLIANCE NOTIFICATION

**FROM:** City of Dumas WWTP  
204 Ford Loop Road  
Dumas, AR 71639

**DATE:** November 11, 2014

**Permit #:** AR0033987

**TO:** NPDES Enforcement  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

1. **DISCHARGE DESCRIPTION: 001**

2. **NON-COMPLIANCE DESCRIPTION:**

Total Residual Chlorine exceeded Instantaneous Max of 0.1 mg/l

3. **CAUSE FOR NON-COMPLIANCE:**

*Auto control val was not adjusting with flow  
was sticking*

4. **DURATION OF NON-COMPLIANCE:**

Two Days, October 14<sup>th</sup> and 16<sup>th</sup>, 2014

5. **CORRECTIVE ACTION BEING TAKEN:**

*Made adjustment to control valve  
cleaned and sprayed lubricant*

**SIGNATURE:** Patrick Fitzgerald

*Patrick Fitzgerald*



CITY OF DUMAS

155 E. Waterman

P. O. Box 157

Dumas, AR 71639-0157

LITTLE ROCK

AR 722

14 NOV '14

PM 3 L



UNITED STATES POSTAGE



PITNEY BOWES

02 1P

\$ 000.48<sup>0</sup>

0004471791 NOV 14 2014

MAILED FROM ZIP CODE 71639

ADEQ  
NPDES ENFORCEMENT BRANCH  
5301 NORTSHORE DR  
NORTH LITTLE ROCK, AR. 72118-5317

72118531799

