

NON-COMPLIANCE NOTIFICATION

FROM: City of Dumas
204 Ford Loop Road
Dumas, AR 71639

DATE: 8/11/2015

PERMIT #: AR0033987

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Fecal Coliform exceeded the 7 Day Geometric value.

3. CAUSE FOR NON-COMPLIANCE:

Leak in Chlorine line


4. DURATION OF NON-COMPLIANCE:

The exceedance took place on Tuesday July 21st, 2015.


5. CORRECTIVE ACTION BEING TAKEN:

Repaired line

SIGNATURE: _____



CITY OF DUMAS
155 E. Waterman
P. O. Box 157
Dumas, AR 71639-0157



ADEQ
NPDES ENFORCEMENT BRANCH
5301 NORTSHORE DR
NORTH LITTLE ROCK, AR. 72118-5317

721185317 7015

