

NON-COMPLIANCE NOTIFICATION

FROM: City of Dumas
204 Ford Loop Road
Dumas, AR 71639

DATE: 10/19/2015

PERMIT #: AR0033987

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The 7 day geo value was reported over the permit limit eleven times in September.

3. CAUSE FOR NON-COMPLIANCE:

Chlorine Auto Valve Not working Proper


4. DURATION OF NON-COMPLIANCE:

The 7 day geo value exceeded permit limits the different times from September 1st-30th.

5. CORRECTIVE ACTION BEING TAKEN:

*Feeding Manually right Now
have one on order*

SIGNATURE: _____



CITY OF DUMAS
155 E. Waterman
P. O. Box 157
Dumas, AR 71639-0157



ADEQ
NPDES ENFORCEMENT BRANCH
5301 NORTSHORE DR
NORTH LITTLE ROCK AR 72118-5317

721185317 0015

