

NON-COMPLIANCE NOTIFICATION

FROM: Dumas Wastewater
P.O. Box 157
Dumas, Ar.
71639

DATE: 10/11/2012

PERMIT NO. AR0033987

TO: NPDES Enforcement
ADEQ
5301 Northshore Dr.
N. Little Rock, Ar. 72118

1. DISCHARGE DESCRIPTION 001
effluent 001A

2. NON-COMPLIANCE DESCRIPTION:

maximum pH of 9.0; Actual pH 9.91

3. CAUSE FOR NON-COMPLIANCE:

Someone is causing the pH to elevate. Thought to be some industry. Influent data for 1 day depicts an orange color to influent water, pH was 6.78 that day. This pH level is also causing the BOD levels to go up.

4. DURATION OF NON-COMPLIANCE: 3 weeks


5. CORRECTIVE ACTION BEING TAKEN: Looking for source -

SIGNATURE

X James Berry

CITY OF DUMAS
155 E. Waterman
P. O. Box 157
Dumas, AR 71639-0157



UNITED STATES POSTAGE

PITNEY BOWES
02 1P \$ 000.45⁰
0004471791 NOV 26 2012
MAILED FROM ZIP CODE 71639

ADEQ
NPDES ENFORCEMENT BRANCH
5301 NORTSHORE DR
NORTH LITTLE ROCK, AR. 72118-5317

721185317 R015

