

From: [Trotta, Jacqueline](#)
To: [Healey, Richard](#)
Cc: [Johnson, Miles](#); [Uyeda, Craig](#)
Subject: RE: Bryant, City of
Date: Monday, June 30, 2014 3:33:00 PM

Richard,

I spoke with Monty Ledbetter with the City of Bryant today. They submitted a report in December 2012 stating that their corrective actions/projects Per the CAO (LIS 06-062) would be completed in October 2013. They said they completed all the work/projects in October 2013. They said they are completely done with all the projects related to that Order. I will check with Miles to see if he had a closure letter signed by the Chief when he closed the Order in ACTION. They said their SSO's have decreased significantly since their corrective actions. He said the majority of the current SSO's have not been related to I & I. issues (like from the Order). He said they've been from power outages. They said they have spare portable generators to bring to the lift stations when they get the alarm that the powers out, but sometimes by the time they get to the lift, there may be some overflow. Since their project completion date of October 2013, the SSO's are as follows:

Location	DateSSOFormReceived	DateOverflowStarted	DateOverflowStopped	TimeOverflowStarted	TimeOverflowStopped	Volume	Stream	Description	Comments
378 Indian Springs Dr., Bryant, AR 72022 - MH# 11275	6/3/2014 0:00	6/2/2014 0:00	6/2/2014 0:00	2:00 PM	3:00 PM	100	SSO Affected Private Property (ground)		
2511 Shadow Creek Dr., Pump Station # 22	5/28/2014 0:00	5/28/2014 0:00	5/28/2014 0:00	11:00 AM	11:30 AM	1000	SSO Affected Private Property (ground)		
3 Neal Dr., Bryant AR 72022 (Behind property)	5/19/2014 0:00	5/19/2014 0:00	5/19/2014 0:00	7:00 AM	9:00 AM	100 GAL	SSO Affected Private Property (ground)		
Elementar School - Manhole # 4572 - to receiving stream	4/10/2014 0:00	4/10/2014 0:00	4/10/2014 0:00	12:00 PM	12:30 PM	300	SSO Reached Receiving Water (river,stream)		
21817 I-30 Pump Station # 7	4/7/2014 0:00	4/7/2014 0:00	4/7/2014 0:00	9:00 AM	9:30 AM	300	SSO Affected Private Property (ground)		Some person or persons dumped a large amount of what appeared to be used motor oil in a man hole out side pump station # 7 which drained into the pump station and caused the pump station to fail and the oil and content overflowed onto the ground. All pert
1103 Boon Road	3/28/2014 0:00	3/27/2014 0:00	3/27/2014 0:00	4:00 PM	4:30 PM	500	SSO Reached Public Land Only (ground)		
3811 Shobe Rd	3/21/2014 0:00	3/21/2014 0:00	3/21/2014 0:00	12:00 PM	12:30 PM	100	SSO Affected Private Property (ground)		
26096 I-30 - overflow - to ground	3/14/2014 0:00	3/14/2014 0:00	3/14/2014 0:00	1:00 PM	1:30 PM	200	SSO Affected Private Property (ground)		county line custom collision
3531 South Shobe Rd. - ground	3/14/2014 0:00	3/13/2014 0:00	3/13/2014 0:00	2:30 PM	3:00 PM	1000	SSO Reached Public Land Only (ground)		6 inch force main break.
4 Tanglewood - Bryant, AR	3/5/2014 0:00	3/4/2014 0:00	3/4/2014 0:00	10:00 PM	11:00 PM	100	SSO Affected Private Property (ground)		
15641 Evergreen Dr. - PS# 5	2/4/2014 0:00	2/4/2014 0:00	2/4/2014 0:00	11:00 AM	11:30 AM	10000	SSO Reached Receiving Water (river,stream)		power failure due to ice storm
4707 N Shobe Rd.	2/3/2014 0:00	2/3/2014 0:00	2/3/2014 0:00	9:00 AM	10:30 AM	500	SSO Affected Private Property (ground)		
2930 Raymar Rd.	1/28/2014 0:00	12/21/2013 0:00	12/21/2013 0:00	10:30 AM	12:00 PM	5000	SSO Reached Public Land Only (ground)		
MHH 4570 Bryant Middle school	1/24/2014 0:00	1/24/2014 0:00	1/24/2014 0:00	1:30 PM	2:30 PM	100	SSO Reached Public Land Only (ground)		
15641 Evergreen Dr.	1/9/2014 0:00	1/9/2014 0:00	1/9/2014 0:00	7:30 AM	8:00 AM	2500	SSO Reached Receiving Water (river,stream)		MH overflow at Pump Station#5 due to power outage.
Manhole # 4570	12/19/2013 0:00	12/18/2013 0:00	12/18/2013 0:00	1:00 PM	1:30 PM	1000	SSO Reached Public Land Only (ground)		
26044 I-30	12/16/2013 0:00	12/16/2013 0:00	12/16/2013 0:00	12:30 PM	1:30 PM	2500	SSO Reached Public Land Only (ground)		1.25 inch force main from E-one PS.

Let me know if you need further information.

Thanks,

Jacqueline Trotta
 Enforcement Analyst
 Water Division
 Arkansas Department of Environmental Quality
 5301 Northshore Drive
 North Little Rock, AR 72118
 501-682-0632

From: Healey, Richard
Sent: Monday, June 30, 2014 8:10 AM
To: Trotta, Jacqueline
Cc: Johnson, Miles; Uyeda, Craig
Subject: FW: Bryant, City of

Jackie
 Please provide Mo an update.
 Thanks
 Richard

From: Uyeda, Craig
Sent: Monday, June 30, 2014 8:09 AM
To: Healey, Richard; Johnson, Miles
Cc: Trotta, Jacqueline
Subject: FW: Bryant, City of

Please update Mo on the above subject.

From: Shafii, Mo
Sent: Monday, June 30, 2014 7:57 AM
To: Uyeda, Craig
Subject: Bryant, City of

Please update me on compliance and SSO for the above city.

Thanks

Mo