

January 25, 2022

Arkansas Department of Environmental Quality  
5301 Northshore Dr.  
North Little Rock, AR 72118-5317

RE: NPDES Permit No. AR34002

City of Bryant, Wastewater Treatment Facility  
1019 SW 2<sup>nd</sup> St.  
Bryant, AR 72022

Date of Non-compliance	Parameter Exceeded	Concentration	Permit Limits
December 6-8	Fecal Coliform	2493/100ml	2000/100ml

We feel this problem was due to:

The samples collected and tested for fecal coliform during the first week of December showed above normal levels. We had a vacuum booster pump failure that resulted in a water pressure drop that reduced the suction from our chlorine regulator. We were able to replace the booster pump and return the system to normal, but the treatment process did not immediately recover to produce an effluent with results that were below the 7-day limit.

Time estimated for corrective action:

Results from the second week of December were below permit limits.

If you have any questions please contact me at [gasher@cityofbryant.com](mailto:gasher@cityofbryant.com)

Gregg Asher  
Treatment Manager  
City of Bryant