

ADEQ

ARKANSAS
Department of Environmental Quality

October 11, 2012

Mr. Greg Asher
City of Bryant Wastewater Treatment Facility
210 Southwest Third Street
Bryant AR 72022

RE: NPDES Permit No. AR0034002, AFIN 63-00065
Updated Operations and Maintenance Procedures

Dear Mr. Asher:

ADEQ has received and reviewed your updated Operations and Maintenance Procedures for the Management of Stormwater Flow at the above facility, dated September 20, 2012. The Department requests that you amend the document to include numeric descriptions of flow rather than narrative descriptions, for example: the section that reads "2. Under dry-weather conditions, flow control valve 1 is open..." should be amended to "2. When flow is less than 2 MGD, flow control valve 1 is open..." and so on. Please re-submit the amended document to the Department by October 26, 2012.

Thank you for your attention in this matter, should you have any questions or concerns, please feel free to contact me at 501-682-0631, or you may e-mail me at johnsonm@adeq.state.ar.us.

Sincerely,



Miles Johnson
Enforcement Analyst
Water Division / Enforcement Branch