

PINE BLUFF WASTEWATER UTILITY

1520 S. OHIO ST. • PINE BLUFF, ARKANSAS 71601-6055 • PHONE: (870) 535-6603 • FAX (870) 535-6243

December 27, 2017

Arkansas Department of Environmental Quality
5301 North Shore Drive
North Little Rock, AR 72118-5317

RE: AR0033316 Sanitary Sewer Overflow

ATTN: Water Quality Enforcement

This letter serves as a follow up report (5-day report) giving a detailed account of the overflow and the steps taken to resolve it. The 24 hour report is on file 15809df0-5d8d-4d4b-b6d2-b795f6739259.

December 23rd, 2017 we became aware of a Sanitary Sewer Overflow (SSO) around 7:00a.m. The address of the overflow was 2703 Port Road, Pine Bluff, AR 71603. This overflow occurred on our mainline due to the pipe condition and excessive rainfall in our area. We were able to re-direct our wastewater flow to minimize the overflow, and on December 24th, 2017, the emergency repair was made to the mainline.

We estimate the volume of overflow around 10,000 gallons with No Evidence of Adverse Health / Environmental Impact (NEAH). The overflow occurred into a yard on private property. The property area will be disinfected and deodorized as well as hydro cleaned for our plans to remediate.

Should there be any further questions or concerns, please feel free to contact me at 870-535-6603.

Sincerely,



Vincent Miles
Environmental Compliance Supervisor

Cc: Ken Johnson, General Manager



PINE BLUFF WASTEWATER UTILITY

1520 S. Ohio Street • Pine Bluff, Arkansas 71601-6055

Serving Our Community, While Protecting The Environment

LITTLE ROCK

AR 722

29 DEC '17

PM 3 1



US POSTAGE

\$ 00.46

First-Class

Mailed From 71601

12/28/2017

032A 0061819804

Arkansas Department of Environmental Quality
ATTN: Water Quality Enforcement
5301 North Shore Drive
North Little Rock, AR 72118-5317

72118-531799

