

October 24, 2022

Arkansas Department of Environmental Quality  
5301 Northshore Dr.  
North Little Rock, AR 72118-5317

RE: NPDES Permit No. AR34002

City of Bryant, Wastewater Treatment Facility  
1019 SW 2<sup>nd</sup> St.  
Bryant, AR 72022

Date of Non-compliance	Parameter Exceeded	7-Day Avg	Permit Limits
September 2022	Ammonia	6.2 mg/l	6.1 mg/l

We feel this problem was due to:

The samples collected and tested for ammonia during the fourth week of August showed above normal levels. We had an equipment failure that resulted in a period of time that the process was without air. The treatment process operated on backup blowers until repairs could be made. However the process did not immediately recover to produce an effluent with results that were able to reduce the 7-day average below the permit limit.

Time estimated for corrective action:

Results from the first week of September were below permit limits.

If you have any questions please contact me at [gasher@cityofbryant.com](mailto:gasher@cityofbryant.com)

Gregg Asher  
Treatment Manager  
City of Bryant