

**BRYANT  
WATER UTILITIES**

May 30, 2014

Arkansas Department of Environmental Quality  
Attn. Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

Re: NPDES Permit No: AR0034002

City of Bryant Wastewater  
1019 S.W. 2<sup>nd</sup> St.  
Bryant, AR 72022

This is a letter informing your office that the Discharge Monitoring Report for April 2014 was not complete until May 30, 2014 due to our office not receiving the results for the analysis performed by our contract lab until May 29, 2014. I have talked with the lab manager at McClelland Consulting Engineers and informed him that we would need to receive the results from the analysis before the week of the 24<sup>th</sup> when the DMR is due to your office.

If you have any questions regarding this matter please contact me at 501 943 0469.



Gregg Asher  
City of Bryant  
Wastewater Treatment Superintendent

# Sanitary Sewer Overflow Monthly Report

## BRYANT, City of

Permit Number 34002

Reporting Period April 2014

No Sanitary Sewer Overflows This Monitoring Period


Location	Man hole#	Start Date of SSO	End Date of SSO	Estimated Volume (gallons)	Cause of SSO	Environmental Impact	Action Taken	Ultimate Discharge Location
21817 I-30 P.S. 7		4/7/14	4/7/14	300	V	NEAH	EC	GR
M.H. # 4572		4/10/14	4/10/14	300	G	NEAH	EC	Correction from CR to GR

**Causes:** CO - Construction  
 E - Equipment Failure  
 HC - Hydro Clean  
 R - Rainfall  
 RO - Roots  
 D - Debris  
 G - Grease  
 LF - Line Failure/Break  
 RG - Roots & Grease  
 V - Vandalism

**SSO Impact:** NEAH - No evidence of Adverse Health or Environmental Impact  
 OEHC - Observed or Evidence of Human Contact  
 EFK - Evidence of Fish Kill

**Action Taken:** WO - Workorder  
 EC - Environmental Cleanup  
 HC - Hydro Cleaned  
 HR - Hand Rodded  
 EN - Referred to Engineering  
 PN - Public Notification

**Ultimate Discharge Location:**  
 CR - Creek/Stream/River (specify)  
 DI - Ditch  
 GR - Ground Surface  
 PA - Paved Area  
 CB - Contained in Building

  
 \_\_\_\_\_  
 Signature of Cognizant or Ranking Official

5/12/14  
 \_\_\_\_\_  
 Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitted false information, including the possibility of fine and imprisonment for knowing violations."

**CERTIFIED MAIL™**

City of Bryant Wastewater  
1019 SW 2nd St.  
Bryant, AR 72022



7010 3090 0002 6036 1613



02 1P  
0003160958 MAY 30 2014  
MAILED FROM ZIP CODE 72022

**\$ 006.48<sup>0</sup>**

Arkansas Dept. of Environmental Quality  
Attn. Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

72118531799

