

# BRYANT WATER UTILITIES

NON-COMPLIANCE LETTER

NOVEMBER 22, 2013

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY  
5301 NORTHSHORE DRIVE  
NORTH LITTLE ROCK, AR 72118-5317  
ATTN: ENFORCEMENT OFFICER

RE: NPDES PERMIT NO: AR0034002

CITY OF BRYANT, WWTP  
1019 SW 2<sup>ND</sup> ST.  
BRYANT, AR 72022  
(501) 943-0469  
GREGG ASHER


DATE OF NON-COMPLIANCE	PARAMETER EXCEEDED	CONCENTRATION	7-DAY	PERMIT LIMITS
10/13	TOTAL SUSPENDED SOLIDS	23.9 mg/l		15 mg/l
10/9-10/11	TOTAL SUSPENDED SOLIDS		33.7 mg/l	22.5 mg/l
10/15-10/17	TOTAL SUSPENDED SOLIDS		38.7 mg/l	22.5 mg/l

WE FEEL THIS PROBLEM WAS DUE TO:  
DURING THE SECOND WEEK OF OCTOBER, OVER THE WEEKEND WE DEVERTED FLOW FROM THE WWTP TO THE EQ BASIN TO LOWER THE WATER LEVEL IN THE FACILITEIS CLARIFIERS AND AERATION BASINS FOR INSPECTION AND PRESSURE WASHING. AFTER HAVING THIS BACK ONLINE WE DISCOVERED THAT THE SETTELING PROCESS HAD BEEN DISRUPETED RESULTING IN A CLOUDY EFFLUENT.

WE PLAN ON CORRECTING THE PROBLEM IN THIS MANNER:  
CLEANING AND INSPECTING THE FACILITIES BASINS ONE SECTION PER WEEK ALLOWING FOR RECOVERY TIME TO THE PROCESS.

TIME ESTIMATED THAT IT WILL TAKE:  
RESULTS FROM WEEK FOUR WERE BELOW THE PERMIT LIMIT

SINCERELY,

  
GREGG ASHER  
TREATMENT SUPERINTENDENT  
CITY OF BRYANT WATER & WASTEWATER

# Sanitary Sewer Overflow Monthly Report

## BRYANT, City of

Permit Number 34002

Reporting Period **October 2013**

No Sanitary Sewer Overflows This Monitoring Period


Location	Man hole#	Start Date of SSO	End Date of SSO	Estimated Volume (gallons)	Cause of SSO	Environmental Impact	Action Taken	Ultimate Discharge Location
125 Dogwood		10/14/13	10/14/13	500	LF	NEAH	EC	GR

**Causes:** CO - Construction  
 E - Equipment Failure  
 HC - Hydro Clean  
 R - Rainfall  
 RO - Roots  
 D - Debris  
 G - Grease  
 LF - Line Failure/Break  
 RG - Roots & Grease  
 V - Vandalism

**SSO Impact:** NEAH - No evidence of Adverse Health or Environmental Impact  
 OEHC - Observed or Evidence of Human Contact  
 EFK - Evidence of Fish Kill

**Action Taken:** WO - Workorder  
 EC - Environmental Cleanup  
 HC - Hydro Cleaned  
 HR - Hand Rodded  
 EN - Referred to Engineering  
 PN - Public Notification

**Ultimate Discharge Location:**  
 CR - Creek/Stream/River (specify)  
 DI - Ditch  
 GR - Ground Surface  
 PA - Paved Area  
 CB - Contained in Building

  
 \_\_\_\_\_  
 Signature of Cognizant or Ranking Official

11/6/13  
 \_\_\_\_\_  
 Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitted false information, including the possibility of fine and imprisonment for knowing violations."

City of Bryant Wastewater  
1019 SW 2nd St.  
Bryant, AR 72022

**CERTIFIED MAIL™**



7010 2780 0001 9214 9579



02 1P  
0003160958 NOV 22 2013  
MAILED FROM ZIP CODE 72022

**\$ 006.11<sup>0</sup>**

Arkansas Dept. of Environmental Quality  
Attn. Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

72118531799

