



A R K A N S A S
Department of Environmental Quality

June 23, 2010

Gayle Stude, Director of Public Works
Yellville, City of
P.O. Box 647
Yellville, AR 72687

RE: NPDES Permit AR0034037, AFIN: 45-00023
Effluent Violations

Dear Mr. Stude:

A recent review of the NPDES file for the City of Yellville has revealed the following effluent violations for the review period of January 1, 2007 through April 30, 2010:

Discharge #	Parameter	Limit Value	DMR Value	% Vio	DMR End Date
001-A	Coliform, fecal general, 7 DA GEO, #/100mL	400	500	25%	6/30/2007
001-A	Nitrite plus nitrate total 1 det. (as N), MO AVG, mg/L	10	10.13	1%	7/31/2007
001-A	Nitrite plus nitrate total 1 det. (as N), 7 DA AVG, mg/L	15	19.51	30%	7/31/2007
001-A	Nitrite plus nitrate total 1 det. (as N), 7 DA AVG, mg/L	15	16.87	12%	8/31/2007
001-A	Nitrogen, ammonia total (as N), MO AVG, mg/L	1	1.2	20%	5/31/2008
001-A	Nitrogen, ammonia total (as N), 7 DA AVG, mg/L	2	2.1	5%	5/31/2008
001-A	Nitrogen, ammonia total (as N), 7 DA AVG, mg/L	2	2.2	10%	6/30/2008
001-A	Coliform, fecal general, 7 DA GEO, #/100mL	400	840	110%	8/31/2008
001-A	Nitrite plus nitrate total 1 det. (as N), MO AVG, mg/L	10	10.2	2%	11/30/2009
001-A	Nitrite plus nitrate total 1 det. (as N), MO AVG, mg/L	10	10.1	1%	1/31/2010

You will need to determine the cause of these effluent violations and work towards compliance.

Any violation of your NPDES Permit is subject to enforcement action by this Department pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or

prevent the occurrence of violations. Violations and non-compliance reports documenting corrective actions are maintained at the Department, and are used to determine possible future enforcement actions by the Department.

Thank you for your attention to this matter. Please refer to NPDES Permit AR0034037 and AFIN 45-00023 in any written correspondence to this Department. Should you have any questions, please feel free to contact me at the 501-682-0823 or you may e-mail me at woodbury@adeq.state.ar.us.

Sincerely,

A handwritten signature in cursive script that reads "Anne Woodbury".

Anne Woodbury
Enforcement Analyst
Water Division Enforcement Branch