



A R K A N S A S
Department of Environmental Quality

June 18, 2013

Stuart L. Oxford
City of Yelleville
P.O. Box 647
Yelleville, AR 72687

RE: NPDES Permit Number AR0034037, AFIN 45-00023
NPDES Permit Effluent Violations

Dear Mr. Oxford,


A recent review of the above referenced permit has revealed the following permit effluent violations for the monitoring period ending April 2013:

DMR End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
01/31/2010	001-A	Nitrite plus nitrate total 1 det. (as N), MO AVG, mg/L	10.	10.1	1%
02/28/2011	001-A	Nitrite plus nitrate total 1 det. (as N), MO AVG, mg/L	10.	10.8	8%
02/28/2011	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	400.	600	50%
09/30/2011	001-A	Nitrite plus nitrate total 1 det. (as N), MO AVG, mg/L	10.	16.1	61%
09/30/2011	001-A	Nitrite plus nitrate total 1 det. (as N), 7 DA AVG, mg/L	15.	23.2	55%
05/31/2012	001-A	Nitrogen, ammonia total (as N), MO AVG, mg/L	1.	<1.2	20%
05/31/2012	001-A	Nitrogen, ammonia total (as N), 7 DA AVG, mg/L	1.5	3	100%
06/30/2012	001-A	Nitrogen, ammonia total (as N), MO AVG, mg/L	1.	1.5	50%
06/30/2012	001-A	Nitrogen, ammonia total (as N), 7 DA AVG, mg/L	1.5	1.9	27%
08/31/2012	001-A	Nitrogen, ammonia total (as N), MO AVG, mg/L	1.	2.1	110%
08/31/2012	001-A	Nitrogen, ammonia total (as N), 7 DA AVG, mg/L	1.5	4.9	227%
09/30/2012	001-A	Nitrogen, ammonia total (as N), MO AVG, mg/L	1.	3.8	280%
09/30/2012	001-A	Nitrogen, ammonia total (as N), 7 DA AVG, mg/L	1.5	6.9	360%
10/31/2012	001-A	Nitrogen, ammonia total (as N), MO AVG, lb/d	6.3	6.4	2%
10/31/2012	001-A	Nitrogen, ammonia total (as N), MO AVG, mg/L	1.	4.4	340%
10/31/2012	001-A	Nitrogen, ammonia total (as N), 7 DA AVG, mg/L	1.5	10.6	607%
01/31/2013	001-A	Nitrogen, ammonia total (as N), MO AVG, mg/L	5.	5.3	6%
01/31/2013	001-A	Nitrogen, ammonia total (as N), 7 DA AVG, mg/L	7.5	9.4	25%
02/28/2013	001-A	Nitrogen, ammonia total (as N), 7 DA AVG, mg/L	7.5	8.1	8%
04/30/2013	001-A	Solids, total suspended, MO AVG, mg/L	15.	<15.1	1%
04/30/2013	001-A	Solids, total suspended, 7 DA AVG, mg/L	23.	34	48%

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit requires you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0823 or e-mail at suel@adeq.state.ar.us.

Sincerely,

A handwritten signature in black ink, appearing to read "K. W. Suel". The signature is fluid and cursive, with the first letters of each word being capitalized and prominent.

Kevin Suel
Enforcement Analyst
Water Division, Enforcement Branch