

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR 0034037 Discharge Number: 001
 Facility: City of Yellville
 Address: 1385 MC 6001
 City: Yellville State: AR Zip: 72687
 Contact: STUART Oxford Phone: 870-656-3705

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
2-7-2019	NITrate & NITrite	438.00 mg/L	438.00 mg/L	15.0 mg/L

We feel this problem was due to:

THE Pumping OF MILK in TO THE Sewer
SYSTEM and THE HIGH Oxygen Demand
IT creates AT THE Waste water plant

We plan on correcting the problem in this manner:

ON 3-27-2019 me and THE Field OFFICER
MEET WITH THE COMPANY ATog TO discuss
OPTION OF WHAT can be done TO STOP
THE problem

Time estimated that it will take to correct problem:

very soon hopefully Now THAT we
Have THE lab RESULTS OF WHAT
They are sending OUT TO THE sewer system

Sincerely, ATTN Danielle Harbin

Stuart Oxford

6-12-2019

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

City of Yellville


Waste Water Treatment Plant

1385 MC 6001

Yellville, AR 72687

NEW ARKANSAS AR 727

13 JUN 2019 PM 2 L



ATTN Danielle Harbin

ADEQ

Water Division, Permits

5301 North Shore Drive

North Little Rock, AR 72118

72118-501799

