

CITY OF YELLVILLE  
WATER AND SEWER DEPARTMENT  
P.O. BOX 647  
YELLVILLE, AR 72687  
(870) 449-5210

December 7, 2021

Arkansas Department of Environmental Quality  
Enforcement Section/ Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Arkansas NPDES Permit Number AR 0034037

Dear Ms. Harbin,

This letter is to inform you of the City of Yellville's non-compliance with effluent limitations for the month of November 2021.

1. Description of Violations:

- a. Dissolved Oxygen, 6.0 (Inst. Min.), reported 4.9.

2. Reason for Violations:

- a. The sludge return line from clarifier #2 was stopped up and the sludge had accumulated to the point where it caused a reduction in the DO.

3. Duration of the Violation:


- a. The sample collected on the 11<sup>th</sup> of November was 4.9 mg/L. The sample on the 18<sup>th</sup> was 6.6.

4. Corrective Action Being Taken to Eliminate Violations:

- a. We jetted the sludge line and got it opened back up and will check the DO on a more frequent basis.

Thank you for your time and considerations. If you should have any questions, please call my office at (870) 449-5210.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Shawn Lane', written over the word 'Sincerely,'.

Shawn Lane, Mayor  
City of Yellville