

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality - Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR 340037 Discharge Number: 001  
Facility: CITY OF YELLVILLE  
Address: 1385 Mc 6001  
City: Yellville State: AR Zip: 72684  
Contact: STUART OXFORD Phone: 1-820-631-9385

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>8/14/2020</u>	<u>NO2+NO3</u>	<u>18.3</u>	<u>18.8</u>	<u>18.8</u>
<u>8/13/2020</u>	<u>NO2+NO3</u>	<u>19.3</u>	<u>19.3</u>	<u>18.8</u>

We feel this problem was due to:

low flows & very high temperatures

We plan on correcting the problem in this manner:

Double checking with the lab to determine if the results were accurate & they were  
Double checking to determine if any fluids were dumped into the sewer system.

Time estimated that it will take to correct problem:

The 3rd samples showed decreased levels

Sincerely,

Stuart Oxford

9/23/2020

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)