

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality - Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0634037 Discharge Number: 001

Facility: CITY OF Yellville

Address: 1385 MC 601

City: Yellville State: AR Zip: 72687

Contact: STUART OXFORD Phone: 1-870-656-9385

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12-17-2020	Fecal Coliform	119.9 CFU	119.9 CFU	400 CFU/100 mL

We feel this problem was due to:
a breaker went bad and THE UV, went down

We plan on correcting the problem in this manner:
The problem was fixed and hopefully THIS will take care of THE problem

Time estimated that it will take to correct problem:
We Hope IT IS Fixed now

Sincerely,
Stuart Oxford

1-2 - 2021

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)