

Arkansas Department of Environmental Quality
Office of Water Quality - Enforcement Branch
5001 Northchase Drive
North Little Rock, AR 72118

EP: Permit No: AR 0034037 Discharge Number: 001
Facility: CITY OF Yellville
Address: 1385 MC 6001
City: Yellville State: AR Zip: 72687
Contact: STUART OXFORD Phone: 870-656-3703

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>2-7-2019</u>	<u>NITRATE & NITRITE</u>	<u>4380 mg/L</u>	<u>438.00 mg/L</u>	<u>15.0 mg/L</u>

We feel this problem was due to:

THE PUMPING OF MILK INTO THE SEWER SYSTEM AND THE HIGH OXYGEN DEMAND IT CREATES AT THE WASTE WATER PLANT

We plan on correcting the problem in this manner:

ON 3-27-2019 ME AND THE FIELD OFFICER MEET WITH THE COMPANY ATG TO DISCUSS OPTIONS OF WHAT CAN BE DONE TO STOP THE PROBLEM

Time estimated that it will take to correct problem:

VERY SOON HOPEFULLY NOW THAT WE HAVE THE LAB RESULTS OF WHAT THEY ARE SENDING OUT TO THE SEWER SYSTEM

Sincerely, ATTN Danielle Harbin

Stuart Oxford

6-12-2019

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)