

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality - Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0034037 Discharge Number: 001
Facility: CITY OF Yellville
Address: 1385 Mc Cool
City: Yellville State: AR Zip: 72687
Contact: STUART OXFORD Phone: 1-870-656-9386

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quantity or Concentration	Permit Limits
1-7-2021	Fecal Coliform	1299.7	1299.7	100 PL

We feel this problem was due to:

I feel THE problem was mishandling
Sampler on are end and THE Labs end
and How they were SHIPPING IT

We plan on correcting the problem in this manner:

The former Employee at THE waste water
plant I fill could have mishandled samples

Time estimated that it will take to correct problem:

THE NEXT 2 samples came back good

Sincerely,

Stuart Oxford

2-18-2021

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)