

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 Office of Water Quality - Enforcement Branch  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: Permit No: AR 0034037 Discharge Number: 001  
 Facility: CITY OF Yellowville  
 Address: ~~1385 Mc 6001~~ 1385 Mc 6001  
 City: Yellowville State: AR Zip: 72687  
 Contact: STUART OXFORD Phone: 1-870-656-9385

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>1-9-2020</u>	<u>CBOP</u>	<u>24.3 mg/l</u>	<u>24.3 mg/l</u>	<u>15.0 mg/l</u>

We feel this problem was due to:  
Washing the post Aerator out  
was done the day before samples

We plan on correcting the problem in this manner:  
Better Caution will be taken in  
the future while I am training a  
new employee

Time estimated that it will take to correct problem:  
problem has been corrected

Sincerely,  
Stuart Oxford 2/23/2020  
 Submitted By: Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)