

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality - Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0034037 Discharge Number: 001
 Facility: CITY OF Yellville
 Address: 1385 Mc 6001
 City: Yellville State: AR Zip: 72687
 Contact: STUART OXFORD Phone: 1-870-656-9585

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
3-18-2021	Fecal Coliforms	> 2419.6	2419.6	400CFU/100ML

We feel this problem was due to:

Keeping the Temperature @ a constant Temperature

We plan on correcting the problem in this manner:

more care will be taking pulling and shipment

Time estimated that it will take to correct problem:

There was only bad sample for the month

Sincerely,

Stuart Oxford

4-21-2021

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)