

CITY OF YELLVILLE  
WATER AND SEWER DEPARTMENT  
P.O. BOX 647  
YELLVILLE, AR 72687  
(870) 449-5210

June 4, 2021

Arkansas Department of Environmental Quality  
Enforcement Section/ Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Arkansas NPDES Permit Number AR 0034037

Dear Ms. Harbin,

This letter is to inform you of the City of Yellville's non-compliance with effluent limitations for the month of April 2021.

1. Description of Violations:

- a. COLIFORM, FECAL, NPDES MAX 400, REPORTED 2419.6.
- b. COLIFORM, FECAL, NPDES MAX 400 REPORTED 3972.5.
- c. COLIFORM, FECAL, NPDES AVG 200 REPORTED 720.4.

2. Reason for Violations:

- a. We are unsure what caused such a high result. We have worked on the UV unit to ensure the proper operation of the unit.
- b. We are unsure what caused such a high result. We have worked on the UV unit to ensure the proper operation of the unit.
- c. We are unsure what caused such a high result. We have worked on the UV unit to ensure the proper operation of the unit.

3. Duration of the Violation:

- a. There were two samples bad in the month of April and that was on the 8<sup>th</sup> and the 22<sup>nd</sup>. The first sample in May was within limits.

4. Corrective Action Being Taken to Eliminate Violations:

- a. More care will be made when collecting the sample to ensure reliable results.
- b. More care will be made when collecting the sample to ensure reliable results.
- c. More care will be made when collecting the sample to ensure reliable results.

Thank you for your time and considerations. If you should have any questions, please call my office at (870) 449-5210.

Sincerely,

Shawn Lane, Mayor  
City of Yellville