

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality - Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0034037 Discharge Number: 001  
Facility: CITY OF Yellville  
Address: 1385 MC 6001  
City: Yellville State: AR Zip: 72687  
Contact: STUART OXFORD Phone: 1-870-656-9385

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
11/19/2020	Fecal Coliforms	689.6 CFU	689.6 CFU	700 CFU/100 ML

We feel this problem was due to:

more care needs to be taken  
when getting samples and keep  
the UV bulbs cleaner

We plan on correcting the problem in this manner:

There was only one bad sample  
for the month

Time estimated that it will take to correct problem:

The next month samples for the  
first of the month came back good

Sincerely,

Stuart Oxford

12-21-2020

Date

Submitted By:

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)