

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality - Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0034037 Discharge Number: 001
 Facility: CITY OF Yellville
 Address: 1385 MC 6001
 City: Yellville State: AR Zip: 72687
 Contact: STUART OXFORD Phone: 1-870-656-9385

| Date of Non-Compliance | Parameter Exceeded | Quantity or Loading | Quality or Concentration | Permit Limits |
|------------------------|-----------------------------------|---------------------|--------------------------|---------------|
| 10-8-2020 | NO ₂ + NO ₃ | 20.6 mg/L | 20.6 mg/L | 15.0 mg/L |
| 10-15-2020 | NO ₂ + NO ₃ | 20 mg/L | 20 mg/L | 15.0 mg/L |
| | | | | |

We feel this problem was due to:

WE MAY HAVE HAD SOMETHING PUT IN THE
COLLECTION SYSTEM AND TEMPERATURE CHANGE

We plan on correcting the problem in this manner:

WE WILL ADJUST THE DISSOLVED OXYGEN
IN AERATION BASIN TO SEE IF THIS HELPS
THE PROBLEM ABOUT LETTING IT HELP TO DENITRIFY.

They estimated that it will take to correct problem:

THE NITRATES + NITRITES HAVE ALREADY
CAME DOWN THIS MONTH SO I THINK
WE HAVE CORRECTED THE PROBLEM

Sincerely,

Stuart Oxford

11/23/2020

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)