

DENNIS BENSON

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: YELLVILLE WASTEWATER

PERMIT: AR0034037 001A

REPORTING PERIOD: NOVEMBER 2015

REPORT DATE: DECEMBER 2015

---

PARAMETER(S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
NO3 + NO2 mg/L		10.00		10.8	*

---

\* Excursion Dates Include: Nov 5th, 12th, 19th.

COMMENTS:

PRINCIPAL EXECUTIVE OFFICER

STUART OXFORD  
YELLVILLE WASTEWATER

TITLE

Waste Water  
Superintendent

DATE

12-16-2015

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 NPDES Enforcement Section  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0034037 Discharge Number: 001-A  
 Facility: City of Yellville Waste Water Treatment Plant  
 Address: 1385 mc 6001  
 City: Yellville State: AR Zip: 72687  
 Contact: STUART OXFORD Phone: 1-870-656-9385

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
11-5-2015	NO <sub>2</sub> + NO <sub>3</sub>			Avg. 10.00
11-12-2015	NO <sub>2</sub> + NO <sub>3</sub>			Results Reported 10.8
11-19-2015	NO <sub>2</sub> + NO <sub>3</sub>			

We feel this problem was due to:

The first sample was the highest  
since we now the aeration bridge turning  
again

We plan on correcting the problem in this manner:

Watching the off on time on the  
blowers

Time estimated that it will take to correct problem:

Hopefully next month

Sincerely,

Stuart Oxford  
 Authorized Signature

12-16-2015  
 Date

City of Yellville  
Waste water Department  
1385 MC 6001  
Yellville, AR 72687

December 16, 2015

Arkansas Department of Environmental Quality  
Enforcement Section/Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Arkansas NPDES Permit Number AR 0034037

Dear Sandy Farmer,

This letter is to inform you of the City of Yellville's non-compliance with effluent limitations for the month of November 2015.

1. Description of Violations:

No3 +No2 mg/L 11/4-18/15                      average 10.8                      NPDES MAX is 10.00

2. Reason for Violations:

The header, which holds the diffusers, came loose. This caused the bridge to quit turning so therefore the samples have been in compliance since the problem has been fixed.

3. Duration of Violation:


I have the sample results from the lab for the rest of November which were in compliance.

Corrective Action Being Taken to Eliminate Violations:

Problem has been taken care although high amounts of rain fall have caused flows to be elevated.

Thank you for your time and considerations. If you have any questions, please call me at 870-656-9385.

Sincerely,



Stuart Oxford Waste Water Superintendent  
City of Yellville

**Sanitary Sewer Overflow Monthly Report**

Facility Name: The City of Yellville Permit Number: AR0034037 Reporting Period (Month/Year):

Nov-15

X No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions

Cause(s) of SSO		Environmental Impact	Action(s) Taken	Ultimate Discharge Location
CO- Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO- Work Order	CR-Creek/Stream/River (Please Specify)
E-Equipment Failure	G-Grease		EC-Environmental Cleanup	DI-Ditch
HC-HydroCleaned	LF-Line failure/ break	OEHC-Observed or Evidence of Human Contact	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots & Grease	EFK-Evidence of Fish Kill	HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole#	Start Date of SSO	End Date Of SSO	Estimated Volume (Gal)	Cause of SSO	Environmental Impact	Action Taken to Address SSO	Ultimate Discharge Location
444 Hwy 62 East		11/17/2015	11/18/2015	25,000	R	NEAH	HC	Town Branch
West 8th Street		11/17/2015	11/18/2015	5,000	R	NEAH	HC	Town Branch
511 Estes		11/17/2015	11/18/2015	8,000	R	NEAH	HC	Town Branch
				38,000 total				

*Shel Oxford*

12-16-2015

Signature of Cognizant or Ranking Official

Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.





**Environmental Services Company, Inc.**

1107 Century

Springdale, AR 72762

479-750-1170 Fax: 479-750-1172



ADEQ  
WATER DIVISION, PERMITS  
5301 NORTHSORE DR.  
NORTH LITTLE ROCK AR 72118