

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0034037 Discharge Number: 1
 Facility: CITY OF Yellville waste water Treatment plant
 Address: 1385 mc 6001
 City: CITY OF Yellville State: AR Zip: 72687
 Contact: STUART OXFORD Phone: 1-870-656-9385

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
8/2-8-2015	NO ₂ + NO ₃			7 Day 15.00
8/9-15-2015	NO ₂ + NO ₃			7 Day 15.00
8/16-22-2015	NO ₂ + NO ₃			7 Day 15.00
				Monthly 10.00

We feel this problem was due to:
Aeration Basin's gear box Had a bearing go out
So it was not turning in 360 degree normal
motion

We plan on correcting the problem in this manner:
Got the approval to order a new Gear Box
which was 3 to 4 weeks out and had
to come from Germany

Time estimated that it will take to correct problem:
I will like by the end of September
it should come down and level out

Sincerely,


 Authorized Signature

9-18-2015

 Date

DENNIS BENSON

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: YELLVILLE WASTEWATER

PERMIT: AR0034037 001A

REPORTING PERIOD: AUGUST 2015

REPORT DATE: SEPTEMBER 2015

PARAMETER(S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
NO3 + NO2 mg/L			15.00	40.6	08/16-22/15
NO3 + NO2 mg/L			15.00	42.0	08/09-15/15
NO3 + NO2 mg/L			15.00	23.5	08/02-08/15
NO3 + NO2 mg/L		10.00		35.3	*

* Excursion Dates Include: Aug 6th, 13th, 20th.

COMMENTS:

PRINCIPAL EXECUTIVE OFFICER

Stuart Oxford
YELLVILLE WASTEWATER

TITLE
waste water
Superintendent

DATE

9-18-2015

City of Yellville
Waste water Department
1385 MC 6001
Yellville, AR 72687

September, 14 2015

Arkansas Department of Environmental Quality
Enforcement Section/Water Division
5301 Northshore Drive
North Little Rock, AR 72118

RE: Arkansas NPDES Permit Number AR 0034037

Dear Sandy Farmer,

This letter is to inform you of the City of Yellville's non-compliance with effluent limitations for the month of August 2015.

1. Description of Violations:

No3 +No2 mg/L 08/02/2015 23.5	NPDES MAX is 15.00
No3+no2 mg/L 08/09/2015 42.0	NPDES MAX is15.00
No3+No2mg/L 08/16/2015 40.6	NPDES MAX is 15.00

2. Reason for Violations:

The gear box which turns the unit in a 360 degree motion went out do to a bearing failure and after approval the parts were ordered, which had to come from Germany, which were 3 to 4 weeks for delivery.

3. Duration of Violation:


I have the sample results from the lab from the first of September which were 16.7 on the no3+no2, which are coming down since the unit is repaired and working.

Corrective Action Being Taken to Eliminate Violations:

Try to rebuild the other parts, so they can be used for future use.

Thank you for your time and considerations. If you have any questions, please call me at 870-656-9385.

Sincerely,

A handwritten signature in black ink, appearing to read "Stuart Oxford". The signature is written in a cursive style with a large initial 'S' and 'O'.

Stuart Oxford Waste Water Superintendent
City of Yellville




Environmental Services Company, Inc.

1107 Century

Springdale, AR 72762

479-750-1170 Fax: 479-750-1172



ADEQ
WATER DIVISION, PERMITS
5301 NORTHSORE DR.
NORTH LITTLE ROCK AR 72118