

DENNIS BENSON

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: YELLVILLE SEWER

PERMIT: AR0034037 001A

REPORTING PERIOD: APRIL 2013

REPORT DATE: MAY 2013

PARAMETER(S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
Solids, TSS mg/L			23.00	34.0	04/07-13/13
Solids, TSS mg/L		15.00		15.1	*

* Excursion Dates Include: Apr 3rd, 10th, 17th.

COMMENTS:

PRINCIPAL EXECUTIVE OFFICER

TITLE

DATE

STUART Oxford
YELLVILLE SEWER

Waste Water Superintendent 5-22-2013