

**City of Yellville**  
WATER AND SEWER DEPARTMENT  
P.O. BOX 647  
YELLVILLE, AR 72687  
(870) 449-5210

June 26, 2012

Mr. Dennis Benson  
Enforcement Administrator  
NPDES Enforcement Section  
State of Arkansas  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, Arkansas 72118-5317

RE: Arkansas NPDES Permit AR0034037, AFIN 45-000

Dear Mr. Benson,

This letter is to inform you of the City of Yellville's non-compliance with effluent Limitations for the month of April 2012.

1. Description of Violations

NH3-N mg/l, NPDES 7 Day AVG 1.5, Reported 3.0

2. Reason for Violations:

a. We believe it to be low levels of oxygen going into our aeration unit.

3. Duration of the Violation:


a. We believe that the low levels happen over a week to two week time.

4. Corrective Action Taken to Eliminate Violations:

a. The aeration unit has 6(six) banks of diffuser's with 30 defussers per bank. We have replaced one bank, and have in stock enough diffusers to replace one more bank. The City has also placed a order for a third set which should arrive some time in July. We feel that with the new diffusers oxygen levels will increase in the aeration unit

Thank you for your time and considerations. If you should have any question, please call my office at (870-449-5210).

Sincerely,



Gayle Stude  
City of Yellville