

March 29, 2013

Mr. Dennis Benson
Enforcement Administrator
NPDES Enforcement Section
State of Arkansas
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118-5317

RE: Arkansas NPDES Permit AR0034037, AFIN 45-000

Dear Mr. Benson,

This letter is to inform you of the City of Yellville's non-compliance with effluent Limitations for the month of February, 2013

1. Description of Violations

- a. NH3-N mg/l, NPDES Max 7.50, Reported 8.1.

2. Reason for Violations:

- a. Due to the motor which drives the main aeration unit going out we had only air going to ¼ of the aeration unit.

3. Duration of the Violation:


- a. The unit was down for approximately 6 days.

4. Corrective Action Taken to Eliminate Violations:

- a. Plant Personnel replaced the motor and a spare motor was order and is in inventory. Upon looking at the next weeks lab analytical data the levels were within limit's.

Thank you for your time and considerations. If you should have any question, please call my office at (870-449-5210).

Sincerely,



Gayle Stude
City of Yellville