

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034037 Discharge Number: 001A  
Facility: Yellville waste water plant  
Address: 1385 MC 6001 Yellville AR 72687  
City: City of Yellville State: AR Zip: 72687  
Contact: Stuart Oxford Phone: 1-870-656-9385

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
1-11-2017	NH3-N	7.98	7.98	7.50

### We feel this problem was due to:

The first samples for february were good. The last sample in january was good so hopefully we will stay in compliance with out anymore breakdowns.


### We plan on correcting the problem in this manner:

We have now replaced both pumps. We went with a better brand pump which is also quicker to get with a better warranty. we also need to keep a spare pump in stock.

### Time estimated that it will take to correct problem:

The first samples for february were good. The last sample in january was good so hopefully we will stay in compliance with out anymore breakdowns.

Sincerely,



Authorized Signature

2-17-2017

Date

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

KEVIN SUEL

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: YELLVILLE WASTEWATER

PERMIT: ar0034037 001a

REPORTING PERIOD: JANUARY 2017

REPORT DATE: FEBRUARY 2017

---

PARAMETER (S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
NH3-N mg/L			7.50	7.98	01/11/17
NH3-N mg/L			7.50	7.98	01/08-14/17

---

COMMENTS :

PRINCIPAL EXECUTIVE OFFICER

  
YELLVILLE WASTEWATER

TITLE

Waste water  
Superintendent

DATE

2-17-2017