

DENNIS BENSON

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: YELLVILLE SEWER

PERMIT: AR0034037 001A

REPORTING PERIOD: JUNE 2012

REPORT DATE: JULY 2012

PARAMETER(S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
NH3-N mg/L			1.50	1.9	06/17-23/12
NH3-N mg/L			1.50	1.7	06/10-16/12
NH3-N mg/L		1.00		1.5	*

* Excursion Dates Include: Jun 6th, 13th, 20th.

COMMENTS:

PRINCIPAL EXECUTIVE OFFICER

TITLE

DATE

Gayle Stude
YELLVILLE SEWER


Dir. of Public Works

8-1-2012



Environmental Services Company, Inc.

1107 Century
Springdale, AR 72762
479-750-1170 Fax: 479-750-1172



ADEQ
Enforcement Section/Water Div.
5301 Northshore Dr.
North Little Rock AR 72118

72118353177015

