

City of Yellville  
Waste Water Treatment Plant  
1385 MC 6001  
Yellville, AR 72687

October, 20 2014

Arkansas Department of Environmental Quality  
Water Division, Permits  
5301 North shore Drive  
North Little Rock, AR 72118

RE: Flow meter struck by lightning

Dear Ms. Leslie Allen -Daniel,

This letter is to inform you of the City of Yellville's situation that occurred due to lightning striking the flow meter.


On October 2, 2014 there was a storm that produced high frequency of lightning and at that time lightning struck the flow meter at the wastewater plant. We were not able to get this flow meter back into operation until October 7<sup>th</sup>.

I had the meter worked on again on October 16<sup>th</sup> so that it could be calibrated again and new parts were added to make the flow meter more accurate. I am checking it multiple times a day to make sure that it is working correctly.

So far the meter is operating appropriately and if anything changes I will be sure to contact you again.

Thank you for your time and considerations. If you have any questions, please call me at 870-656-9385.

Sincerely,

A handwritten signature in black ink that reads "Stuart Oxford". The signature is written in a cursive style with a large initial "S" and "O".

Stuart Oxford Waste Water Superintendent  
City of Yellville

City of Yellville

Waste Water Treatment Plant

1385 MC 6001

Yellville, AR 72687

NW ARKANSAS AR 727

20 OCT 2014 PM 1 L



ADEQ

Water Division, Permits

5301 North Shore Drive

North Little Rock, AR 72118

7211865317

