

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034037 Discharge Number: 001A

Facility: Yellville waste water plant

Address: 1385 MC 6001 Yellville AR 72687

City: City of Yellville State: AR Zip: 72687

Contact: Stuart Oxford Phone: 1-870-656-9385

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
1-11-2017	NH3-N	7.98	7.98	7.50

We feel this problem was due to:

The first samples for february were good. The last sample in january was good so hopefully we will stay in compliance with out anymore breakdowns.

We plan on correcting the problem in this manner:

We have now replaced both pumps. We went with a better brand pump which is also quicker to get with a better warranty. we also need to keep a spare pump in stock.

Time estimated that it will take to correct problem:

The first samples for february were good. The last sample in january was good so hopefully we will stay in compliance with out anymore breakdowns.

Sincerely,



Authorized Signature

2-17-2017

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034037 Discharge Number: 001A

Facility: Yellville waste water plant

Address: 1385 MC 6001 Yellville AR 72687

City: City of Yellville State: AR Zip: 72687

Contact: Stuart Oxford Phone: 1-870-656-9385

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
1-11-2017	NH3-N	7.98	7.98	7.50

We feel this problem was due to:

The first samples for february were good. The last sample in january was good so hopefully we will stay in compliance with out anymore breakdowns.


We plan on correcting the problem in this manner:

We have now replaced both pumps. We went with a better brand pump which is also quicker to get with a better warranty. we also need to keep a spare pump in stock.

Time estimated that it will take to correct problem:

The first samples for february were good. The last sample in january was good so hopefully we will stay in compliance with out anymore breakdowns.

Sincerely,



Authorized Signature

2-17-2017

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034037 Discharge Number: 001A
Facility: Yellville waste water Plant
Address: 1385 mc 6001 Yellville AR 72687
City: CITY OF Yellville State: AR Zip: 72687
Contact: STUART OXFORD Phone: 1-877-656-9385

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>1-11-2017</u>	<u>NH3-N</u>	<u>7.98</u>	<u>7.98</u>	<u>7.50</u>

We feel this problem was due to:

We Had a another Return Activated
Sludge pump up, we Had to RENT a diesel
pump to Return Sludge around THE clock
and the Aeration Basins Bridge was stopped

We plan on correcting the problem in this manner:

We Have now replaced BOTH pumps,
we went with a better Brand WHICH is
also quicker to get with a better warranty

Time estimated that it will take to correct problem:

THE FIRST samples for February are good,
THE last sample in January was good
so Hopefully we will stay in compliance

Sincerely,

Stuart Oxford

Authorized Signature

2-17-2017

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

KEVIN SUEL

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: YELLVILLE WASTEWATER

PERMIT: ar0034037 001a

REPORTING PERIOD: JANUARY 2017

REPORT DATE: FEBRUARY 2017

PARAMETER (S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
NH3-N mg/L			7.50	7.98	01/11/17
NH3-N mg/L			7.50	7.98	01/08-14/17

COMMENTS:

PRINCIPAL EXECUTIVE OFFICER


YELLVILLE WASTEWATER

TITLE

waste water
superintendent

DATE

2-17-2017

KEVIN SUEL

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: YELLVILLE WASTEWATER

PERMIT: ar0034037 001a


REPORTING PERIOD: JANUARY 2017

REPORT DATE: FEBRUARY 2017

PARAMETER (S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
NH3-N mg/L			7.50	7.98	01/11/17
NH3-N mg/L			7.50	7.98	01/08-14/17

COMMENTS :

PRINCIPAL EXECUTIVE OFFICER



YELLVILLE WASTEWATER

TITLE

Waste Water
Superintendent

DATE


2-17-2017

City of Yellville

Waste Water Treatment Plant

1385 MC 6001

Yellville, Arkansas 72687



ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
NPDES ENFORCEMENT SECTION
5301 NORTHSHORE DRIVE
NORTH LITTLE ROCK, AR 72118
ATTN. SANDY FARMER