

DENNIS BENSON

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: YELLVILLE WASTEWATER

PERMIT: AR0034037 001A

REPORTING PERIOD: SEPTEMBER 2015

REPORT DATE: OCTOBER 2015

---

PARAMETER(S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
NO3 + NO2 mg/L			15.00	16.7	08/30-05/15

---

COMMENTS:

PRINCIPAL EXECUTIVE OFFICER

STUART OXFORD  
YELLVILLE WASTEWATER

TITLE

WASTE WATER  
SUPERINTENDENT

DATE

10-21-2015

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 NPDES Enforcement Section  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0034037 Discharge Number: 001-A  
 Facility: CITY OF Yellville  
 Address: 1385 mc 6001  
 City: Yellville State: AR Zip: 72687  
 Contact: STUART OXFORD Phone: 1-870-656-9385

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
9-3-2015	NO <sub>2</sub> +NO <sub>3</sub> 76.7			15.00

We feel this problem was due to:  
The Aeration Bridge NOT Turning as Normal

We plan on correcting the problem in this manner:  
I HAVE THE REST OF SAMPLES and I HAVE IT BACK TO NORMAL

Time estimated that it will take to correct problem:  
I HAVE THE FIRST SAMPLES FOR OCTOBER BACK and we are BACK in COMPLIANCE

Sincerely,  
  
 \_\_\_\_\_  
 Authorized Signature

10-21-2015  
 \_\_\_\_\_  
 Date

City of Yellville  
Waste water Department  
1385 MC 6001  
Yellville, AR 72687

October 21, 2015

Arkansas Department of Environmental Quality  
Enforcement Section/Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Arkansas NPDES Permit Number AR 0034037

Dear Sandy Farmer,

This letter is to inform you of the City of Yellville's non-compliance with effluent limitations for the month of September 2015.

1. Description of Violations:

No3 +No2 mg/L 08/02/2015 16.7

NPDES MAX is 15.00

2. Reason for Violations:

The gear box which turns the unit in a 360 degree motion went out do to a bearing failure and after approval the parts were ordered, which had to come from Germany, which were 3 to 4 weeks for delivery.

3. Duration of Violation:

I have the sample results from the lab for the rest of September which were in compliance.

Corrective Action Being Taken to Eliminate Violations:

Problem has been taken care of.

Thank you for your time and considerations. If you have any questions, please call me at 870-656-9385.

Sincerely,



Stuart Oxford Waste Water Superintendent  
City of Yellville




**Environmental Services Company, Inc.**

---

1107 Century

Springdale, AR 72762

479-750-1170 Fax: 479-750-1172



ADEQ  
WATER DIVISION, PERMITS  
5301 NORTHSORE DR.  
NORTH LITTLE ROCK AR 72118