

**Sanitary Sewer Overflow Monthly Report**

**Facility Name: The City of Yellville Permit Number: AR0034037 Reporting Period (Month/Year):**

**Oct-15**

**X No Sanitary Sewer Overflows This Monitoring Period**

**Summary Report Code Descriptions**

Cause(s) of SSO		Environmental Impact	Action(s) Taken	Ultimate Discharge Location
CO- Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO- Work Order	CR-Creek/Stream/River (Please Specify)
E-Equipment Failure	G-Grease		EC-Environmental Cleanup	DI-Ditch
	LF-Line failure/ break	OEHC-Observed or Evidence of Human Contact	HC-Hydro Cleaned	DR-Drop Inlet
HC-HydroCleaned			HR-Hand Rodded	GR-Ground Surface
R-Rainfall	RG-Roots & Grease	EFK-Evidence of Fish Kill	EN-Referred to Engineering	PA-Paved Area
RO-Roots	V-Vandalism		PN-Public Notification	CB-Contained in Building

Location	Manhole#	Start Date of SSO	End Date Of SSO	Estimated Volume (Gal)	Cause of SSO	Environmental Impact	Action Taken to Address SSO	Ultimate Discharge Location

*Short signed*  
 \_\_\_\_\_  
 Signature of Cognizant or Ranking Official

*11-16-2015*  
 \_\_\_\_\_  
 Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

City of Yellville  
Waste water Department  
1385 MC 6001  
Yellville, AR 72687

November 16, 2015

Arkansas Department of Environmental Quality  
Enforcement Section/Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Arkansas NPDES Permit Number AR 0034037

Dear Sandy Farmer,

This letter is to inform you of the City of Yellville's non-compliance with effluent limitations for the month of October 2015.

1. Description of Violations:

No3 +No2 mg/L 10/18-24/15 18.4 NPDES MAX is 15.00

2. Reason for Violations:

The header, which holds the diffusers, came loose. This caused the bridge to quit turning so therefore the samples have been in compliance since the problem has been fixed.

3. Duration of Violation:


I have the sample results from the lab for the rest of October which were in compliance.

Corrective Action Being Taken to Eliminate Violations:

Problem has been taken care of.

Thank you for your time and considerations. If you have any questions, please call me at 870-656-9385.

Sincerely,



Stuart Oxford Waste Water Superintendent  
City of Yellville

DENNIS BENSON

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: YELLVILLE WASTEWATER

PERMIT: AR0034037 001A

REPORTING PERIOD: OCTOBER 2015

REPORT DATE: NOVEMBER 2015

---

PARAMETER(S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
NO3 + NO2 mg/L			15.00	18.4	10/18-24/15
NO3 + NO2 mg/L		10.00		11.4	*

---

\* Excursion Dates Include: Oct 8th, 15th, 22nd.

COMMENTS:

PRINCIPAL EXECUTIVE OFFICER

  
YELLVILLE WASTEWATER

TITLE  
WASTE WATER  
Superintendent

DATE

11-16-2015




**Environmental Services Company, Inc.**

---

1107 Century

Springdale, AR 72762

479-750-1170 Fax: 479-750-1172



ADEQ  
WATER DIVISION, PERMITS  
5301 NORTSHORE DR.  
NORTH LITTLE ROCK AR 72118