



ARKANSAS
Department of Environmental Quality

November 15, 2011

Mr. Carl Wheatley
City of Malvern
P.O. Box 638
Malvern, AR 72104

RE: NPDES Permit No. AR0034126, AFIN 30-00040

Dear Mr. Wheatley:

A review of the NPDES file for the City of Malvern for the period of August 1, 2011 thru August 31, 2011 reveals the following compliance issue:

The facility reported 1 violation of Part I, Section A. of NPDES Permit No.: AR0034126. The effluent violation reported on the DMR is as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
08/31/2011	001-A	pH (MAXIMUM, SU)	9.5	9

The Department assumes that the City of Malvern continues to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at anderson@adeq.state.ar.us.

Sincerely,

Alan Anderson
Enforcement Analyst
Water Division / Enforcement Branch

