

Richard Healey (adpce.ad)

From: Devan Baugh <dbaugh@malvernar.gov>
Sent: Tuesday, February 6, 2024 11:41 AM
To: SSOADEQ
Cc: John Davis; Carl Wheatley
Subject: E- Coli Report

We "Malvern Waste Water" had an over flow occur at Kelly Morztet these are the results from testing

Sample site 1 was collected 2/4/24 at 10:55 AM and incubated at 11:15 AM and removed at 11:15AM 2/5/24 with results greater than 2419.6

With sample site 1 being greater than 2419.6 we are required to grab samples from sample sites 3 and 4

Sample site 3 was collected 2/5/24 at 11:32 AM and incubated at 11:40 AM 2/5/24 and removed at 11:40AM 2/6/24 with results of 133.4

Sample site 4 was collected 2/5/24 at 11:25 AM and incubated at 11:40 AM 2/5/24 and removed at 3:13 PM 2/6/24 with results of 517.2