

Kristen Graham (adpce.ad)

Subject: Ecoli report from 5/3/2024

From: Devan Baugh <dbaugh@malvernar.gov>

Sent: Monday, May 6, 2024 2:10 PM

To: SSOADEQ <SSOADEQ@adeq.state.ar.us>

Cc: John Davis <jdavis@malvernar.gov>

Subject: Ecoli report from 5/3/2024

We Malvern Waste water had an overflow occur on 5/3/24 at Intersection of Kelly and Morzett street

These are the results from testing

Sample site #1 was grabbed at 10:30 AM on 5/3/24 and incubated at 10:56AM 5/3/24 And removed from incubator at 10:40 AM on 5/4/24 with results greater than 2419.6

Sample site #3 was grabbed at 10:37 AM on 5/3/24 and incubated at 10:56AM 5/3/24 And removed from incubator at 10:40 AM on 5/4/24 with results greater than 2419.6

Sample Site #4 was grabbed at 10:46 AM on 5/3/24 and incubated at 10:56AM 5/3/24 And remove from incubator at 10:40 Am on 5/4/24 with results greater than 2419.6