



June 18, 2024

VIA E-MAIL: Kristen.Graham@adeq.state.ar.us

Ms. Kristen Graham
Compliance Analyst, OWQ, DEQ
5301 Northshore Drive
North Little Rock, AR 72118-5317

RE: City of Malvern, Arkansas
NPDES Permit No. AR0034126, AFIN 30-00040
CAO LIS 24-045
Monthly Progress Report 02

Dear Ms. Graham:

The hydraulic modeling workshop referenced in Monthly Progress Report 01 has been scheduled for June 28, 2024. No other corrective actions have been performed since the last progress report.

Table 1 summarizes the SSOs at manholes #154 & #155 during the reporting period ending May 31, 2024.

MH No.	Start Date	End Date	Cause	Estimated Volume	Remediation Action	Sample Site & Date	<i>E. coli</i> Results
154	5/23/2024, 9AM	5/23/2024, 12PM	I&I - Rainfall, 1 pump down at Walco LS	13,750 gallons	No solids observed, no clean-up required	Site 1, 2, 3, & 4 5/23/2024	>410 cfu/100ml
155	5/23/2024, 9AM	5/23/2024, 12PM	I&I - Rainfall, 1 pump down at Walco LS	27,500 gallons	No solids observed, no clean-up required		
155	5/24/2024, 6:20AM	5/24/2024, 1PM	I&I - Rainfall, 1 pump down at Walco LS	50,000 gallons	No solids observed, no clean-up required	Site 2, 3, & 4 5/24/2024	>410 cfu/100ml
154	5/25/2024, 7AM	5/25/2024, 7PM	I&I - Rainfall, 1 pump down at Walco LS	65,000 gallons	No solids observed, no clean-up required	Site 2, 3, & 4 5/25/2024	>410 cfu/100ml

Table 1: SSOs at Manholes #154 & #155

The City of Malvern notified the public in accordance with the approved communication plan. Should you have any questions or concerns, please don't hesitate to reach out anytime at 501.664.1552.

Ms. Kristen Graham
NPDES Permit No. AR0034126, AFIN 30-00040
CAO LIS 24-045
Progress Report 02
Page 2 of 2

Sincerely,
Crist Engineers, Inc.

A handwritten signature in blue ink, appearing to read "Mason Allen", with a stylized, flowing script.

Mason Allen, P.E.

Cc: Honorable Brenda Weldon, Mayor, City of Malvern
David Coston, General Manager, Malvern Water Works
Carl Wheatley, Superintendent, Malvern Water Works