



506 Overman Street  
P.O. Box 638  
Malvern Arkansas 72104

501 332-3634, Phone  
501 332-5730, Facsimile

10/04/12

ADEQ  
NPDES Enforcement Section  
5301 Northshore Dr.  
North Little Rock, AR 72118-5317

**Re: Permit Number AR0034126**

**In response to the 2 DMR Exemptions for Chlorine, Total Residual**

We had two exemptions on Chlorine, Total Residual for the month of September. When the first one was realized, we made an adjustment to our Sulfur Dioxide. The next day, when our reading was still above our limit, we started looking elsewhere for our problem. In doing so, we found that there was a hole in the Sulfur Dioxide feed line, which was allowing air to be sucked instead of the product. After the hole repaired, our readings went back to normal.

Sincerely,

A handwritten signature in black ink, appearing to read "Carl Wheatley". The signature is written in a cursive style with a large, looping initial "C".

Carl Wheatley  
Wastewater Supervisor


Doing Our Best

**MALVERN WATER WORKS**



for You.

506 Overman Street  
P.O. Box 638  
Malvern, Arkansas 72104



ADEQ

Water Division - Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR

72118-5317

721185317

