


Sanitary Sewer Overflow Monthly Report

Facility Name: Malvern Water Works Permit Number: AR0034126 Reporting Period (Month/Year): Oct. 2014

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions				
Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order	CR-Creek/Stream/River (Please Specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots & Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Description								
Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location
1600 BK Pine Dr.	0872	10/14	10/14	1000	G	NEAH	JET Rod	GR
City Park Hwy 270	L5	10/31	10/31	1500	E	NEAH	WO	GR, CR
Dead End - Overman St.	0830	10/16	10/16	10000	G	NEAH	JET Rod	GR

Signature of Cognizant or Ranking Official

Date

11/03/2014

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violation."



506 Overman Street
P.O. Box 638
Malvern Arkansas 72104

501 332-3634, Phone
501 332-5730, Facsimile

11/06/14

ADEQ
NPDES Enforcement Section
5301 Northshore Dr.
North Little Rock, AR 72118-5317

Re: Permit Number AR0034126

In response to the 3 DMR Exemptions for NH3


Malvern Wastewater has three exemptions for NH3. We were unable to run NH3 for the week of October 5 due to a malfunction of our probe. The probe was erratic when measuring standards. We did maintenance by changing the fluid and membrane. The same problem persisted. A new probe was ordered but did not arrive in time to do any testing for that particular week.

Sincerely,

Carl Wheatley
Wastewater Supervisor

Doing Our Best

MALVERN WATER WORKS



for You

506 Overman Street
P.O. Box 638
Malvern, Arkansas 72104

LITTLE ROCK AR 722

05 NOV 2014 PM 4 11



ADEQ

WATER DIVISION-ENFORCEMENT BRANCH
5301 NORTSHORE DRIVE
NORTH LITTLE ROCK, AR 72118-5317

72118531799

