



506 Overman Street
P.O. Box 638
Malvern Arkansas 72104

501 332-3634, Phone
501 332-5730, Facsimile

05/14/2015

ADEQ
Gina Porter
NPDES Enforcement Section
5301 Northshore Dr.
North Little Rock, AR 72118-5317

Re: Permit Number AR0034126

Monthly DMR of February 1 – 28, 2015

In response to the 1 DMR Exemptions for NH3 of the monthly average/max of 10

As you are aware from near past issues concerning exemptions with NH3, while training of a new employee during the month of February 2015, the wrong solutions were used in maintenance of probe.

Fix: Proper training of the new operator by the Chief Operator in maintenance of probes.

No issues were found in April, 2015

Sincerely,

A handwritten signature in black ink, appearing to read "Carl Wheatley".

Carl Wheatley
Wastewater Supervisor



506 Overman Street
P.O. Box 638
Malvern Arkansas 72104

501 332-3634, Phone
501 332-5730, Facsimile

05/14/2015

ADEQ
Gina Porter
NPDES Enforcement Section
5301 Northshore Dr.
North Little Rock, AR 72118-5317

Re: Permit Number AR0034126

Monthly DMR of March 1 – 31, 2015

In response to the 1 DMR Exemptions for NH3 of the monthly lbs./max of 254

Due to our rainfall in the month of March, 2015, we had one of our top five discharge months since 2003. We averaged 4.8 million gallons per day for the month of March '15. Due to levels of ponds, we were unable to slow the rate of the discharge, thus the exemption in pounds for NH3.

Fix: To our knowledge, due to the circumstances involving the rainfall and depth of ponds, there is really no way to fix this problem other than stopping or control the flow.


Sincerely,

A handwritten signature in black ink, appearing to read "Carl Wheatley", with a stylized flourish at the end.

Carl Wheatley
Wastewater Supervisor

Doing Our Best

MALVERN WATER WORKS



for You.

506 Overman Street
P.O. Box 638
Malvern, Arkansas 72104

LITTLE ROCK AR 722

14 MAY 2015 PM 3 L



ADEQ
Gina Porter
NPDES Enforcement Section
5301 Northshore Dr.
N. Little Rock, AR 72118-5317

72118531799

