Sanitary Sewer Overflow Monthly Report

Facility Name: Malvern Water Works Permit Number: AR0034126 Reporting Period (Month/Year): Decembee, 2012

No Sanitary	Sewer	Overflows	This	Monitoring Period	

		Summary Report Code Desc	riptions		
Cause(s	s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location	
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order	CR-Creek/Stream/River (Please Specify)	
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch	
HC-Hydro Clean	LF-Line Failure Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet	
R-Rainfall	RG-Roots & Grease		HR-Hand Rodded	GR-Ground Surface	
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area	
10-1000			PN-Public Notification	CB-Contained in Building	

Description

				Description				· · · · · · · · · · · · · · · · · · ·
Location	Manhole#	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location
int. of Wilson/Royal Oaks	1147	12/7	12/7	20,000	G	NEAH	367 Vac	GR/PA
27305. River Cleak DR.	FORE Main		/2/13	2100	Co	NEAH	Wo	GR
1503 MISSISSIPPI	4" Cleanoo		12/17	30	6/5	NEAH	JET Vac	GR
		•						
	<u> </u>							

Signature of Cognizant or Ranking Official

1/7/2013

[&]quot;I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violation."