

## Sanitary Sewer Overflow Monthly Report

Facility Name: Malvern Water Works Permit Number: AR0034126 Reporting Period (Month/Year): February, 2013

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions			
Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup
HC-Hydro Clean	LF-Line Failure Break	EFK-Evidence of Fish Kill	DI-Ditch
R-Rainfall	RG-Roots & Grease	HR-Hand Rodded	DR-Drop Inlet
RO-Roots	V-Vandalism	EN-Referred to Engineering	GR-Ground Surface
		PN-Public Notification	PA-Paved Area
			CB-Contained in Building


Description								
Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location
1920 Robert E. Lee	cleanout	2/6/13	2/6/13	200	G	NEAH	Jet Vac	GR
Jrt. Oaklawn/Dyer	0555	2/11/13	2/11/13	55	G	NEAH	Jet Vac	GR
4-H Club Hwy 270	Rg. Pump	2/13/13	2/13/13	400	E	NEAH	WO	GR
1103 Harper	10' Line	2/14/13	2/14/13	250	LF	NEAH	WO	GR

*Carl [Signature]*

2-28-2013

Signature of Cognizant or Ranking Official \_\_\_\_\_ Date \_\_\_\_\_

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violation."



506 Overman Street  
P.O. Box 638  
Malvern Arkansas 72104

501 332-3634, Phone  
501 332-5730, Facsimile

03/08/13

ADEQ  
NPDES Enforcement Section  
5301 Northshore Dr.  
North Little Rock, AR 72118-5317

**Re: Permit Number AR0034126**

**In response to the 1 DMR Exemptions for Chlorine, Total Residual**

Our relief operator let the sulphur dioxide run out. The operator has been talked to about the importance of checking chemicals daily.

Sincerely,

Carl Wheatley  
Wastewater Supervisor

Doing Our Best

**MALVERN WATER WORKS**



for You.

506 Overman Street  
P.O. Box 638  
Malvern, Arkansas 72104

LITTLE ROCK AR 722

08 MAR 2013 PM 4 12



Freedom  
FOREVER

Justice  
FOREVER

ADEQ

Water Division - Enforcement Branch

5301 Northshore Drive

N. Little Rock, AR

72118-5317

72118531799

