

Sanitary Sewer Overflow Monthly Report

Facility Name: Malvern Water Works Permit Number: AR0034126 Reporting Period (Month/Year): 3/2015

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions

Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup
HC-Hydro Clean	LF-Line Failure Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned
R-Rainfall	RG-Roots & Grease	HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism	EN-Referred to Engineering	PA-Paved Area
		PN-Public Notification	CB-Contained in Building

Description

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location
City Park - MLK Blvd.	LS	3/23/15	3/23/15	100	E	NEAH	WO	GR / CR
Dead End Overman St.	630	3/13/15	3/15/15	58,000	R	NEAH	WO/EN	GR / DI
Int. Sheppard + Sect. Line	371	3/13/15	3/13/15	500	R	NEAH	WO/EN	GR / CR
712 S Wako	08, 09	3/13/15	3/14/15	8500	R	NEAH	WO/EN	GR / DI / CR
Int. Kelly + Morzette	86	3/10/15	2/10/15	1000	R	NEAH	WO/EN	GR
City Park - MLK Blvd.	LS	3/7/15	3/7/15	250	E	NEAH	WO	GR / CR
City Park - MLK Blvd.	LS	3/3/15	3/3/15	100	E	NEAH	WO	GR

Carl [Signature]

4/2/2015


Signature of Cognizant or Ranking Official

Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violation."

Doing Our Best

MALVERN WATER WORKS



for You.

506 Overman Street
P.O. Box 638
Malvern, Arkansas 72104

LITTLE ROCK AR 72114

08 APR 2015 PM 4



ADEQ

WATER DIVISION-ENFORCEMENT BRANCH

5301 NORTHSORE DRIVE

NORTH LITTLE ROCK, AR 72118-5317

72118531799

