



## Department of Public Works

3/27/2013

Lindsay Copenhagen  
ADEQ – Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

Wastewater Department  
Kathryn Catlin  
Wastewater Systems Manager  
1508 Silver Valley Road  
Harrison, Arkansas 72601  
Office: 870.741.5527  
Fax: 870.741.0318  
[www.cityofharrison.com](http://www.cityofharrison.com)  
[kathryn.catlin@cityofharrison.com](mailto:kathryn.catlin@cityofharrison.com)

**RE: Notification of Equipment Failure – City of Harrison Permit No. AR0034321**

Dear Lindsay;

The impeller on the south aeration basin at the City of Harrison Wastewater Treatment Plant that mixes the wastewater has unexpectedly failed. In the past the facility has been able to meet all permit requirements without the south basin in operation. We will make the necessary adjustments to transfer the existing flow from the south aeration basin to the north basin.

An engineer has been hired to determine the cause of the failure and to select replacement equipment, which is denoted as Phase II Improvements on the attached schedule. As you can see on the schedule, the facility is presently in the middle of Phase I of the improvements.

If you have any questions or require any additional information, please feel free to contact me at 870-741-5527 or [Kathryn.catlin@cityofharrison.com](mailto:Kathryn.catlin@cityofharrison.com).

Sincerely,

Kathryn Catlin  
Wastewater Systems Manager