

## Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City of Harrison NPDES Permit No.: AR0034321 Monitoring Period (Month/Year): 08 / 2020

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions								
Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location					
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental. Impact	CR-Creek/Stream/River (specify)					
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup				DI-Ditch	
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	HC-Hydro Cleaned				DR-Drop Inlet	
R-Rainfall	RG-Roots / Grease		HR-Hand Rodded				GR-Ground Surface	
RO-Roots	V-Vandalism		EN-Referred to Engineering				PA-Paved Area	
			PN-Public Notification				CB-Contained in Building	
Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
403 Peeble Beach	10-388	8/24/2020	8/24/2020	300	RO	NEAH	HC	GR

  
 Signature of Cognizant or Ranking Official Date September 11, 2020

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."