

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City of Harrison

NPDES Permit No.: AR0034321

Monitoring Period (Month/Year): 02 / 2022

No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		Summary Report Code Descriptions			Action(s) Taken	Ultimate Discharge Location
		SSO Impact				
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental Impact				CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup			DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	HC-Hydro Cleaned			DR-Drop Inlet
R-Rainfall	RG-Roots / Grease		HR-Hand Rodded			GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering			PA-Paved Area
			PN-Public Notification			CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
1703 Daly Drive	10-242	2/10/2022	2/10/2022	100	RG	NEAH	HC	GR
904 Hester	11-218	2/11/2022	2/11/2022	20	RO	NEAH	HC	GR
N Oak & W. Bower	8-82	2/13/2022	2/13/2022	200	G	NEAH	HC	DR
Hickory/Stephenson	7-26A, 26-28	2/19/2022	2/19/2022	10	HC	NEAH	HC	GR
100 S Highland	7-55 & 53	2/26/2022	2/26/2022	10	D	NEAH	HC	GR
				340				

Kathryn Callin

Signature of Cognizant or Ranking Official

March 15, 2022

Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."