

ADEQ

ARKANSAS
Department of Environmental Quality

December 23, 2014

Kathryn Catlin
City of Harrison
P.O. Box 1715
Harrison, AR 72601

RE: NPDES Permit Number: AR0034321 AFIN: 05-00054

Dear Ms. Catlin,

The Department has performed a compliance review for the above referenced facility from June 2014 to present. It revealed the following violations:


The facility has reported **3 effluent violations** of Part I, Section A. of NPDES Permit No. AR0034321:

Dsch#	Parameter	Limit Value	DMR Value	DMR End Date	Violation Code	% Vio	Parameter Code
001-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	39.	73.9	08/31/2014	E90	89%	00610-1-0
001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	1.8	3.95	08/31/2014	E90	119%	00610-1-0
001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	4.6	5.38	08/31/2014	E90	17%	00610-1-0

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0630, or you may e-mail me at allen-daniel@adeq.state.ar.us.

Sincerely,



Leslie Allen-Daniel
Enforcement Analyst
Water Division, Enforcement Branch